

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

648010

COUNTY LUCAS TOWNSHIP ADAMS SECTION OF TOWNSHIP #18

OWNER MEDICAL COLLEGE OF OHIO ADDRESS 3000 Arlington Avenue

LOCATION OF PROPERTY TOLEDO, OHIO

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (specify one by circling)
Casing diameter <u>8"</u> Length of casing <u>93'4"</u>	Test rate <u>300</u> gpm Duration of test _____ hrs
Type of screen <u>NONE</u> Length of screen _____	Drawdown <u>35</u> ft Date _____
Type of pump <u>NONE INSTALLED AT THIS TIME</u>	Static level (depth to water) <u>62</u> ft
Capacity of pump _____	Quality (clear, cloudy, taste, odor) <u>clear</u>
Depth of pump setting _____	Pump installed by <u>NOT COMPLETED AT THIS TIME</u>
Date of completion <u>JUNE 28, 1989</u>	

WELL LOG*			SKETCH SHOWING LOCATION
Formations: sandstone, shale, limestone, gravel, clay	From	To	Locate in reference to numbered state highways, street intersections, county roads, etc.
TOP SOIL	0 ft	1 ft	N S W E Arlington Ave. 3/8 mile 3/8 mile 8" Well Glendale Ave. Byrne Rd
YELLOW & GREENISH CLAY	1	10	
SOFT SANDY GRAY CLAY	10	30	
STONEY GRAY CLAY	30	68	
SOFT SANDY GRAY CLAY	68	74	
STONEY GRAY CLAY	74	84	
STONEY HARDPAN (HARD)	84	90	
GRAY LIME STONE (HARD)	90	95	
DARK GRAY LIME STONE (VERY HARD)	95	115	
SIREAKS OF GRAY & BROWN LIME STONE	115	120	
BROWN LIME STONE W/SIREAKS OF GRAY LIME STONE	120	145	
BROWN LIME STONE	145	215	
LIGHT GRAY RO WHITE LIME STONE	215	260	
LIGHT GRAY LIME STONE	260	280	
BROWN LIME STONE	280	310	

DRILLING FIRM DUNBAR-STARK DRILLING INC.
ADDRESS 2997 TREAT HIGHWAY

DATE 7/25/89
SIGNED Mary R Stark

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224