WELL LOG AND DRILLING REPORT

NO CARBON PAPER NECESSARY – SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

651113

COUNTY Wood TOWNSHIP Weston SECTION OF TOWNSHIP

OWNER Shawn Bradford ADDRESS 14100 Rt 235

LOCATION OF PROPERTY About 2 miles South on Rt 235 off of Rt 6 on East Side

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 82'6"

Type of screen Length of screen

Type of pump Submersible

Capacity of pump 10 gpm

Depth of pump setting 110'

Date of completion 7-17-85

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 3 gpm Duration of test — hrs

Drawdown 105 ft Date 7-12-85

Static level (depth to water) 14'5" ft

Quality (clear, cloudy, taste, odor)

Pump installed by Williams Well Drilling

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Fill Clay	0 ft	2' 6" ft
SAND	2' 6"	10' 6"
Clay/gravel mix	10' 6"	23'
Small gravel	23'	27' 6"
Limestone	27' 6	100
	[redacted]	/
WATER	96'?	

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Williams Well Drilling DATE 7-12-85