

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

651809

COUNTY Stark TOWNSHIP Tuscarawas SECTION OF TOWNSHIP 8
OWNER Bennitt Co. ADDRESS 14852 Lincoln Way Rt 172
LOCATION OF PROPERTY Dalton, O. corner Alabama & Lincoln Way

CONSTRUCTION DETAILS

203 Well
Casing diameter 7" OD Length of casing 246'
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST

(specify one by circling)

air test

Test rate 60 gpm Duration of test 2 hrs
Drawdown ft Date Oct 31 1985
Pumping
Static level (depth to water) 300' ft
Quality (clear) cloudy, taste, odor)
Pump installed by Larry Pugh Well & Pump

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay


From

To

<u>M. clay & Stones</u>	0 ft	<u>15</u> ft
<u>gr. shale</u>	<u>15</u>	<u>40</u>
<u>Sandrock</u>	<u>40</u>	<u>45'</u>
<u>blue Sandys shale</u>	<u>45</u>	<u>62</u>
<u>limestone</u>	<u>62</u>	<u>68</u>
<u>coal</u>	<u>68</u>	<u>70</u>
<u>blue Sandys shale</u>	<u>70</u>	<u>89</u>
<u>limestone</u>	<u>89</u>	<u>93</u>
<u>Sandrock</u>	<u>93</u>	<u>106</u>
<u>gr. Sandys shale</u>	<u>106</u>	<u>141</u>
<u>Soft shale</u>	<u>141</u>	<u>150</u>
<u>blue Sandys shale</u>	<u>150</u>	<u>156</u>
<u>Sandrock</u>	<u>156</u>	<u>168</u>
<u>Shale</u>	<u>168</u>	<u>227</u>
<u>coal</u>	<u>227</u>	<u>229</u>
<u>light shale</u>	<u>229</u>	<u>235</u>
<u>gr. Sandys shale</u>	<u>235</u>	<u>332</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM

Davidson Drilling

DATE

Nov 4 1985

ADDRESS

7160 Beechwood ave.

SIGNED

John I. Davidson

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224