

653563

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number _____

COUNTY Adams TOWNSHIP York SECTION OF TOWNSHIP T275B 28
OWNER Ron Nison ADDRESS 15425 Bennett Rd Nelsonville Ohio
LOCATION OF PROPERTY 1

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 1/2 Length of casing 127
Type of screen None Length of screen
Type of pump Deep well
Capacity of pump ~~270~~ 10 gpm 3/4
Depth of pump setting 210 feet
Date of completion May 28 88
Rotary ☐ or Cable ☒

Test rate 15 gpm Duration of test 27 hrs
Drawdown _____ ft Date May 28-88
Static level (depth to water) 63 feet ft
Quality (clear, cloudy, taste, odor) Cloudy
Pump installed by Miller water well Driller

SKETCH SHOWING LOCATION

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

	0 ft	ft
Gray Clay		
Black Shale	0	10
Gray Sandstone	10	29
Black Shale	29	42
Gray Shale	42	48
Gray Shale	48	60
Coal	60	102
Gray Shale	102	104
Gray Shale	104	110
Gray Shale	110	122
Gray Shale	122	130
White Clay	130	140
Gray Shale	140	178
Coal	178	179
Gray Shale	179	197
Gray Sand	197	200
	200	223

[illegible]

* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM McIntosh and Wells REGISTRATION NUMBER

RATE Low 2 00