

653844

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
Fountain Square  
Columbus, Ohio 43224

Permit Number 75366

COUNTY Huron TOWNSHIP Ripley SECTION OF TOWNSHIP \_\_\_\_\_  
OWNER Richard Pennell ADDRESS RT 1 4472 Township 111 Ply Ohio  
LOCATION OF PROPERTY 1/2 mile South of 224 ON East End

**BAILING OR PUMPING TEST**  
(specify one by circling)

Test rate 6 gpm Duration of test 2 hrs

Drawdown 20 ft Date July 28, 1988

Static level (depth to water) 20.5 ft

Quality (clear, cloudy, taste, odor) See

Pump installed by Olvera

Date of completion July 28, 1988  
Rotary ☐ or Cable ☒

Rotary ☐ or Cable ☒

**SKETCH SHOWING LOCATION**

To

Locate in reference to numbered state highways, street intersections, county roads, etc.

0 ft

70 ft

20

55

55

25

25

125

125

130

Water at 75-110

**W**

E

9

\* If additional space is needed to complete well log, use next consecutively numbered form.

**DNR 7802**

DRILLING FIRM Exxon Drilling REGISTRATION NUMBER

572

DATE July 28, 1988

ADDRESS RD #4 Ashland OH 4480

**SIGNED**

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

**WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy**

1080 CR 2075

