

658163

Permit Number 62-202-87

COUNTY Wayne TOWNSHIP Chippewa SECTION OF TOWNSHIP 17
OWNER James O. ~~Black~~ Ashley ADDRESS 189 Black Dr. Dryestown, Ala.
LOCATION OF PROPERTY 1155 S. Portage Dr. Dryestown, Ala. 34230

BAILING OR PUMPING TEST
(Specify one by circling)

Test rate 10 gpm Duration of test 3 hrs
Drawdown 15 ft Date _____
Static level (depth to water) 90 ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by Clinton Hall & Pinedale Inc

SKETCH SHOWING LOCATION

[illegible]

Locate in reference to numbered
state highways, street intersections, county roads, etc.

A hand-drawn map of the Easton area. The map is oriented with North (N) at the top, South (S) at the bottom, East (E) to the right, and West (W) to the left. A road labeled "AKRON RD" runs diagonally from the bottom-left towards the top-right. A point on this road is labeled "EASTON". To the right of the road, there is a small, irregularly shaped lake labeled "DONNA LAKE". Further to the right and slightly above the lake, there is a label "X well". A line segment connects the "EASTON" point to the "X well" label. The number "585" is written near the "EASTON" point.

DNR 7802

DRILLING FIRM Clinton Well & Pump REGISTRATION NUMBER 174 DATE 9-12-87
ADDRESS 4034 Manchester Rd Akron, Ohio SIGNED John H. Magaw

WHITE - ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy

