

659579

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 101-94

COUNTY Hocking TOWNSHIP Laurel SECTION OF TOWNSHIP _____
OWNER Robert Cupp ADDRESS 23088 Bigham Road
LOCATION OF PROPERTY 23088 Bigham Road Rockbridge

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 157 gpm Duration of test 1 hrs

Drawdown 6 ft Date 8-18-94

Static level (depth to water) 0 ft

Quality (clear, cloudy, taste, odor) _____

Pump installed by Chuck Mock

Pump installed by Chuck Mock

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Surface.	0 ft	4 ft
Brown sand	4'	24'
gray sand	24'	40'
white sand	40'	100'

A hand-drawn map showing the intersection of Bigham Road and ST Route 374. The map is oriented with North (N) at the top, South (S) at the bottom, East (E) on the right, and West (W) on the left. Bigham Road runs from the west towards the intersection. ST Route 374 runs north-south. A well, marked with an 'x', is located south of the intersection. A north arrow is present in the bottom right corner.

* If additional space is needed to complete well log, use next consecutively numbered form.

REGISTRATION NUMBERS

SIGNED Charles Mack

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy

3407

