

WELL LOG AND DRILLING REPORT

659870

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 17559

COUNTY Ashland TOWNSHIP Orange SECTION OF TOWNSHIP _____
OWNER Jack Keller ADDRESS 609 Twp Rd. 671 Rt #3 Ashland
44805
LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 43' 6"
Type of screen stainless steel .040 Length of screen 45'
Type of pump Submersible
Capacity of pump 10 GPM
Depth of pump setting 41'
Date of completion 7-13-91
Rotary ☐ or Cable ☒

BAILING OR PUMPING TEST

(specify one by circling)


Test rate 20+ gpm Duration of test 4 hrs
Drawdown 5' ft Date 7-12-91
Static level (depth to water) 24' ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by Lee's Pump & Well Service

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>Top Soil + Sand + gravel</u>	<u>0 ft</u>	<u>9 ft</u>
<u>Blue Clay</u>	<u>9</u>	<u>39</u>
<u>Sand + Gravel</u>	<u>39</u>	<u>42</u>
<u>Screen set 40'-42'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM Lee's Pump & Well Service REGISTRATION NUMBER 1064 DATE 7-17-91
ADDRESS 341 C SR 511 Nova, Ohio 44859 SIGNED Lee Bolland

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy