

660855

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 67-87

COUNTY PERRY TOWNSHIP THORN SECTION OF TOWNSHIP _____
OWNER PAUL GRIMM ADDRESS BOX 383 THORNVILLE, O.
LOCATION OF PROPERTY 14656 ZION RD, THORNVILLE O.

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter 5.5" Length of casing 55.33'
Type of screen P. PIPE Length of screen 1'
Type of pump SHALLOW WELL JET
Capacity of pump 15 G.P.M.
Depth of pump setting 34'
Date of completion 9/21/87
Rotary ☐ or Cable ☒

Test rate 12 gpm Duration of test 1 hrs
Drawdown 13 ft Date 9/14/87
Static level (depth to water) 7 ft
Quality (clear, cloudy, taste, odor) SMALL AMOUNT
OF FINE SAND
Pump installed by HOOVER WELL DRILLING

SKETCH SHOWING LOCATION

To

Locate in reference to numbered state highways, street intersections, county roads, etc.

CLAY	0 ft	42 ft
SAND (FINE) + WATER	42'	43'
CLAY	43'	50'
SAND	50'	52'

WAZL 53'

A hand-drawn map showing the intersection of Honey Creek Rd and Blackbird Rd. A well is marked near the intersection. The map is oriented with North (N) at the top, South (S) at the bottom, West (W) on the left, and East (E) on the right. A road labeled 'Zion Rd' runs diagonally from the bottom left towards the intersection. A road labeled 'SR. #13' runs vertically from the intersection towards the bottom. A circular stamp in the bottom right corner reads 'LOCATED 49'.

* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM HOOVER WELL DRILLING REGISTRATION NUMBER 1138 DATE 9/22/87
ADDRESS 18 SUMMIT RD, THORNVILLE, OH SIGNED D.P. Hoover

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy