

661888

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 43-90

COUNTY Perry TOWNSHIP Reading SECTION OF TOWNSHIP 13

OWNER Pete Pineda ADDRESS Somerset

LOCATION OF PROPERTY 1/2 mile S.E. of 669 on Route 13 6606 ST. RT 13

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter 7" Length of casing 31'6"

Test rate 24 gpm Duration of test 24 hrs

Type of screen shot Length of screen

Drawdown 25" ft Date June 22, 1990

Type of cures

Static level (depth to water) 18 ft

Capacity of pump

Quality (clear, cloudy, taste, odor) _____

Depth of pump setting

Pump installed by _____

Date of completion...
Rotary ☐ or Cable ☒

SKETCH SHOWING LOCATION

**Formations: sandstone, shale,
limestone, gravel, clay**

From

To

yellow sand	0 ft	10 ft
-------------	------	-------

Dark Shd.	10	22
-----------	----	----

Gray shale	22	43
------------	----	----

Heat	45	47
------	----	----

Grey Sheb	47	67
-----------	----	----

Total Depth	67	
-------------	----	--

24 GPM

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

~~STATE 13~~ ~~STATE 169~~

5

E

LOCATED
171

S

* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM Ralph Morgan REGISTRATION NUMBER 1430 DATE 6/22/90

ADDRESS Somerset 6 5416 SIGNED Ralph Morgan

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy