

WELL LOG AND DRILLING REPORT

666974

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number E2211

COUNTY DARKE TOWNSHIP BROWN SECTION OF TOWNSHIP 10

OWNER TED TRITTSCHUH ADDRESS 11207 MICHAEL RD. ANSONIA O.

LOCATION OF PROPERTY RT 118 NORTH OF ANSONIA TO BROWN RD LEFT TO MICHAEL RD
1ST HOUSE ON RIGHT

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 98'
Type of screen — Length of screen —
Type of pump INSTALLED BY OTHER
Capacity of pump —
Depth of pump setting —
Date of completion 8-11-88
Rotary ☐ or Cable ☒

BAILING OR PUMPING TEST

(specify one by circling)


Test rate 20 gpm Duration of test 24 hrs
Drawdown 12' ft Date 8-11-88
Static level (depth to water) 42' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by OWNER

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>CLAY</u>	<u>0 ft</u>	<u>75 ft</u>
<u>SAND</u>	<u>75</u>	<u>98</u>
<u>GRAVEL</u>	<u>98'</u>	<u>WATER</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM GARRISON WELL DRILLING REGISTRATION NUMBER 984 DATE 5-16-89

ADDRESS 5612 HARTZELL RD GREENVILLE O SIGNED [Signature]

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy