

666976

Permit Number E 7444

COUNTY DARKE TOWNSHIP GREENVILLE SECTION OF TOWNSHIP 30
OWNER DAYE MEYER ADDRESS 1360 UNION CITY RD GREENVILLE
LOCATION OF PROPERTY 5877 REQUARTH ROAD GREENVILLE, OHIO

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (specify one by circling)
Casing diameter <u>5 5/8</u> Length of casing <u>100'</u>	Test rate <u>12</u> gpm Duration of test <u>4</u> hrs
Type of screen <u>—</u> Length of screen <u>—</u>	Drawdown <u>10</u> ft Date <u>10-13-89</u>
Type of pump <u>NOT INSTALLED</u>	Static level (depth to water) <u>54'</u> ft
Capacity of pump <u>—</u>	Quality (clear, cloudy, taste, odor) <u>CLEAR</u>
Depth of pump setting <u>—</u>	
Date of completion <u>10-13-89</u> Rotary ☐ or Cable ☒	Pump installed by <u>NONE INSTALLED</u>

[illegible]

DNR 7802

WHITE ORIGINAL COPY - OONR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy

