

WELL LOG AND DRILLING REPORT

667777

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number #336-88

COUNTY Hancock TOWNSHIP Amanda SECTION OF TOWNSHIP _____
OWNER Don Mathias ADDRESS 100 W. Main St.
LOCATION OF PROPERTY Same Vanlue, OH

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 26'
Type of screen _____ Length of screen _____
Type of pump Submersible
Capacity of pump 15 gpm
Depth of pump setting 35'
Date of completion June 2, 1988
Rotary ☐ or Cable ☒

BAILING OR PUMPING TEST (specify one by circling)


Test rate 15 gpm Duration of test 2 hrs
Drawdown _____ ft Date _____
Static level (depth to water) 12 ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by Spencer Drilling, Inc.

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>yellow clay</u>	<u>0 ft</u>	<u>10 ft</u>
<u>blue clay</u>	<u>10</u>	<u>14</u>
<u>limestone</u>	<u>14</u>	<u>40</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DRILLING FIRM Spencer Drilling REGISTRATION NUMBER 255 DATE 6-2-88

ADDRESS _____ SIGNED _____

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy