

670646

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number WI 9100080

OWNER Don Bottoms ADDRESS _____

LOCATION OF PROPERTY 7686 BRAUN RD.

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter <u>4 1/4</u>	Length of casing <u>90</u>	Test rate <u>16</u> gpm	Duration of test <u>6</u> hrs
Type of screen _____	Length of screen _____	Drawdown <u>NONE</u> ft	Date _____
Type of pump _____		Static level (depth to water) <u>17 ft</u>	ft
Capacity of pump _____		Quality (clear, cloudy, taste, odor) _____	
Depth of pump setting _____			
Date of completion <u>JUNE 7, 1991</u>		Pump installed by _____	
Rotary ☐ or Cable ☒			

SKETCH SHOWING LOCATION

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

CLAY	0 ft	62 ft
SAND	62	75
SAND + GRAVEL	75	90
PEPE CASING		

A hand-drawn map on a white background. At the top is a bold black 'N' for North. At the bottom is a bold black 'S' for South. On the left is a bold black 'W' for West, and on the right is a bold black 'E' for East. A horizontal line represents Hayes Rd., with the text 'HAYES RD.' written above it. A vertical line represents Brauk Rd., with the text 'BRAUK RD.' written to its left. The two roads intersect at a right angle.

DNR 7802

DRILLING FIRM SAM Lewis REGISTRATION NUMBER 182 DATE JUNE 1, 1991

ADDRESS 1913 TODD AVE. SIGNED Sam Lewis

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept Copy