

670991

DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 799

COUNTY Licking TOWNSHIP Madison SECTION OF TOWNSHIP 4
OWNER Arthur Ross III ADDRESS 3075 Collins Rd
LOCATION OF PROPERTY 3065 Collins Rd Newark

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter <u>5</u> Length of casing <u>90'</u>	Test rate <u>15</u> gpm Duration of test <u>24</u> hrs
Type of screen <u>none</u> Length of screen <u>none</u>	Drawdown <u>70</u> ft Date <u>3-14</u>
Type of pump <u>Submersible</u>	Static level (depth to water) <u>50'</u> ft
Capacity of pump <u>10 g.p.m.</u>	Quality (clear, cloudy, taste, odor) <u>Clear</u>
Depth of pump setting <u>80'</u>	
Date of completion <u>3-15-82</u>	Pump installed by <u>Denman Drilling</u>
Rotary ☐ or Cable ☒	

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Top soil	0 ft	1 ft
Brown shale	1	15
Blue Mud	15	65
Brown shale	65	80
Brown sand stone	80	100

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

Collins Rd

septic

70' well
40' → X

W

F

S

* If additional logs are needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM Desman Drilling REGISTRATION NUMBER 1161 DATE 3-16-92

ADDRESS 679 Boston Rd NE Nashport O SIGNED Dennis Wenman

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue Customer's Copy / Pink - Driller's Copy / Green Local Health Dept. Copy