

671014

Permit Number 371392

COUNTY MARION TOWNSHIP Waldo SECTION OF TOWNSHIP 17
OWNER DAVE & Judy Haubert ADDRESS 5832 ST. JAMES Rd
LOCATION OF PROPERTY 1/4 Mi S. of ~~Harriet~~ Rd P.O. Rengert.

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>5"</u>	Length of casing <u>40'</u>	Test rate <u>12</u> gpm	Duration of test <u>4</u> hrs
Type of screen <u>PERF.</u>	Length of screen <u>4'</u>	Drawdown <u>5'</u> ft	Date <u>26 June 91</u>
Type of pump <u>SUB</u>		Static level (depth to water) <u>14'</u> ft	
Capacity of pump <u>15 G.P.M.</u>		Quality (clear, cloudy, taste, odor) <u>CLEAR</u>	
Depth of pump setting <u>40'</u>			
Date of completion <u>27 June 91</u>		Pump installed by <u>HINES</u>	
Rotary ☒ or Cable ☐			

[illegible]

DNR 7802

DRILLING FIRM Thomas Drilling REGISTRATION NUMBER 14-24 DATE 27 June 91
ADDRESS Ashley Ohio SIGNED E. L. Nier

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy