

671367

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number _____

COUNTY Windsor TOWNSHIP Hunter SECTION OF TOWNSHIP

OWNER Paul J. Adams ADDRESS 4993 Kennesaw Dr.

LOCATION OF PROPERTY 240 Bull Road

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter 5 5/8 Length of casing 26

Test rate 10 gpm Duration of test 1 hrs

Type of screen 70 Length of screen

Drawdown 30 ft Date 29 July 88

Type of pump _____

Static level (depth to water) 14 ft

Capacity of pump _____

Quality (clear, cloudy, taste, odor) Clear

Depth of pump setting _____

Pump installed by _____

Date of completion
Rotary ☐ or Cable ☒

SKETCH SHOWING LOCATION

**Formations: sandstone, shale,
limestone, gravel, clay**

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Sandy Clay	0 ft	16 ft
Limestone	16	60
Blue Rock	60	75
Red Rock	75	80
Blue Rock.	80	150

Resmed & Cemented
to 25'

W

E

S

* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM Talbotson Well Co. REGISTRATION NUMBER 184 DATE 10 May 2012

ADDRESS 1821 Indiana St. SIGNED S. C. Fallerson

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue - Customer's Copy / Pink - Driller's Copy / Green - Local Health Dept. Copy