

671784

Permit Number 6291

COUNTY Warren TOWNSHIP Franklin SECTION OF TOWNSHIP City
OWNER Robert R. Reed ADDRESS 492 Central Ave
LOCATION OF PROPERTY 492 Central Ave Charles Okin #5005

BAILING OR PUMPING TEST
(specify one by circling)

Casing diameter <u>4 in</u>	Length of casing <u>52 ft</u>	Test rate <u>15</u> gpm	Duration of test <u>5</u> hrs
Type of screen <u>None</u>	Length of screen _____	Drawdown <u>2 ft</u> ft	Date <u>June 13, 1991</u>
Type of pump <u>1/2 H.P. Sta Rita</u>		Static level (depth to water) <u>32 ft</u> ft	
Capacity of pump <u>10-12 gal min</u>		Quality (clear, cloudy, taste, odor) <u>Clear</u>	
Depth of pump setting <u>47 ft</u>			
Date of completion <u>June 14, 1991</u>		Pump installed by <u>W. Hugh Tucker</u>	
Rotary ☐ or Cable ☒		<u>Well Drilling</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Slut.	0 ft	8.	ft
Sand gravel -	8	12	
Yellow Clay.	12	20	
Sand & Gravel.	20	52	

Filled Old Well up
With Cement.

W

N

ad
well

new Well
E

Very Sincerely
Central Ave.

S

DNR 7802

DRILLING FIRM Deugh Tucker Well Drilling REGISTRATION NUMBER 0674 DATE June 14, 1991

ADDRESS 135 N. Elm St 2d Cavalton SIGNED Hugh Fincher

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue Customer's Copy / Pink - Driller's Copy / Green Local Health Dept. Copy