

671952

Columbus, Ohio 43224

Permit Number _____

Permit Number _____

COUNTY Seneca TOWNSHIP Seneca SECTION OF TOWNSHIP _____

OWNER Michael A. Walter ADDRESS 6755 S. SENECA TR54

LOCATION OF PROPERTY 6701 S. SENECA TR54

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>5 1/2"</u>	Length of casing _____	Test rate <u>18</u> gpm	Duration of test <u>1 1/2</u> hrs
Type of screen <u>✓</u>	Length of screen <u>—</u>	Drawdown <u>3</u> ft	Date <u>7/24/87</u>
Type of pump <u>—</u>		Static level (depth to water) <u>34</u> ft	
Capacity of pump <u>—</u>		Quality (clear, cloudy, taste, odor) <u>Clear</u>	
Depth of pump setting <u>—</u>			
Date of completion <u>7/24/87</u>		Pump installed by _____	
Rotary ☒ or Cable ☐			

[illegible]

DNR 7802

DRILLING FIRM AAA Well Drilling REGISTRATION NUMBER _____ DATE 1-90

ADDRESS 3433 N. W. 107th Ave. #125 SIGNED _____

Completion of this form is required by 1521.05, Ohio Revised Code file within 30 days after completion.

WHITE ORIGINAL COPY - ODMR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue Customer's Copy / Pink - Driller's Copy / Green Local Health Dept. Copy