

WELL LOG AND DRILLING REPORT

671954

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number

76-89

COUNTY Seneca TOWNSHIP Eden SECTION OF TOWNSHIP _____

OWNER Geneva Hopkins ADDRESS 4693 So Co Rd 19

LOCATION OF PROPERTY South of 45224 about 2 1/2 mi.

CONSTRUCTION DETAILS

Casing diameter 5 1/2 Length of casing 74

Type of screen none Length of screen —

Type of pump Burke

Capacity of pump 600 GPR

Depth of pump setting 60'

Date of completion 7-1-89

Rotary ☐ or Cable ☐

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 18 gpm Duration of test 1 hrs

Drawdown 4 ft Date 7-1-89

Static level (depth to water) 29 ft

Quality (clear, cloudy, taste, odor) clear

Pump installed by aaa Well Drilling

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To

YELLOW & BLUE CLAY 0 ft 70 ft

LIME STONE 70 80

SKETCH SHOWING LOCATION


Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

E

S



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802

DRILLING FIRM aaa Well Drilling REGISTRATION NUMBER 1627 DATE 7-18-89

ADDRESS 3255 So Twp Rd 195 Tiffin SIGNED James C. Scharber

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion.

WHITE ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / Blue Customer's Copy / Pink Driller's Copy / Green Local Health Dept. Copy