

673333

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

Permit Number 228B

Permit Number 2200
COUNTY LUCAS TOWNSHIP PROVIDENCE SECTION OF TOWNSHIP _____
OWNER COUNTRY CAMP Ground ADDRESS 8664 YAWBERG Rd. - W. H. T. Hous
LOCATION OF PROPERTY SAME (GLENN + DARLA MCGINLEY)

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 15 gpm Duration of test 1 hrs

Drawdown 0 ft Date 2-23-88

Static level (depth to water) 30 ft. ft

Quality (clear, cloudy, taste, odor) _____

Clear-Sulphur

Pump installed by TIPLADY & MEYER

WELL LOG*

SKETCH SHOWING LOCATION

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Sand.

0 ft

/ ft

Clay

✓

30

Livingstone

70

135

Water at 134 ft.

A hand-drawn map on a grid background. A horizontal line is labeled 'W' at the left end and 'E' at the right end. A vertical line is labeled 'S' at the bottom end. The text 'WATERVILLE NEAPOLIS' is written across the top of the horizontal line. Below this, the word 'WELL.' is written, followed by a small square symbol. Further down, the word 'DORAN' is written across the horizontal line. A second horizontal line is drawn below 'DORAN'.

* If additional space is needed to complete well log, use next consecutively numbered form.

DRILLING FIRM WILSON & MEYER REGISTRATION NUMBER 61

DNR 7802

ADDRESS 446 MADISON WHITEHOUSE ON/O

DATE 3-85