

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224

685499

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number 69-94

COUNTY Hocking TOWNSHIP Starr SECTION OF TOWNSHIP 21
OWNER Linda Carter PROPERTY ADDRESS 20576 St. Rt. 328, New Plymouth
LOCATION OF PROPERTY Same Ohio 45654

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (specify one by circling)
CASING Casing Diameter <u>5</u> " in. Length of Casing <u>266</u> ft. Type: ☐ Steel ☐ Galv. ☒ PVC ☐ Other Joints: ☐ Threaded ☐ Welded ☒ Solvent ☐ Other	WELL TEST Test rate <u>over 10</u> gpm Duration of test <u>2 1/2</u> hrs. Drawdown (water level during pumping) _____ ft. Measured from: ☐ top of casing ☐ ground level ☐ Other Static Level (depth to water) <u>225</u> ft. Date: <u>6-29-94</u> Quality (clear, <u>cloudy</u> , taste, odor) _____
SCREEN Type (wire wrapped, louvered, etc.) _____ Material _____ Length _____ ft. Diameter _____ in. Set between _____ ft. and _____ ft. Slot _____	PUMP Type of pump <u>Submersible 1 1/2 HP</u> Capacity <u>10</u> gpm Pump set at <u>400</u> ft. Pump installed by <u>Lowell Reinschell Drilling</u>
GROUT Material <u>Cement</u> Volume used _____ Method of installation <u>fill back approx 40' cement</u> Depth: placed from <u>266</u> ft. to <u>226</u> ft. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other	Pitless Device ☒ Adapter ☐ Preassembled unit Use of Well <u>Home</u>

WELL LOG*	From	To	SKETCH SHOWING LOCATION
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand			Show distances well lies from numbered state highways, street intersections, county roads, etc.
<u>Top Soil</u>	<u>0</u> ft.	<u>1</u> ft.	
<u>Fire Clay</u>	<u>1</u>	<u>6</u>	
<u>Gray Shale</u>	<u>6</u>	<u>28</u>	
<u>Sandy Gray Shale</u>	<u>28</u>	<u>68</u>	
<u>Gray Shale</u>	<u>68</u>	<u>118</u>	
<u>Black Shale</u>	<u>118</u>	<u>142</u>	
<u>Gray Shale</u>	<u>142</u>	<u>187</u>	
<u>Sand</u>	<u>187</u>	<u>205</u>	
<u>Gray Shale</u>	<u>205</u>	<u>240</u>	
<u>Sand</u>	<u>240</u>	<u>245</u>	
<u>Gray Shale</u>	<u>245</u>	<u>404</u>	
<u>Injun Sand</u>	<u>404</u>	<u>417</u>	
<u>Water at 411</u>			

* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM Lowell Reinschell Drilling SIGNED Lowell Reinschell
 ADDRESS 20107 St. Rt. 328 DATE 6-29-94
 CITY, STATE, ZIP New Plymouth, Ohio 45654 ODH REGISTRATION NUMBER 529

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
 Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy