

# WELL LOG AND DRILLING REPORT

103

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
1939 Fountain Square Drive  
Columbus, Ohio 43224

689726

TYPE OR USE PEN  
SELF-TRANSCRIBING  
PRESS HARD!

Permit Number W.370-88

COUNTY Wayne TOWNSHIP Congress SECTION OF TOWNSHIP \_\_\_\_\_  
OWNER Fred Scherfenout PROPERTY ADDRESS 7180 Twp Rd 102  
LOCATION OF PROPERTY South Side of Twp Rd. 102

## CONSTRUCTION DETAILS

**CASING**  
Casing Diameter 5 in. Length of Casing 90 ft.  
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other \_\_\_\_\_  
Joints: ☐ Threaded ☐ Welded ☐ Solvent ☐ Other \_\_\_\_\_  
**SCREEN**  
Type (wire wrapped, louvered, etc.) \_\_\_\_\_ Material \_\_\_\_\_  
Length \_\_\_\_\_ ft. Diameter \_\_\_\_\_ in.  
Set between \_\_\_\_\_ ft and \_\_\_\_\_ ft Slot \_\_\_\_\_  
**GROUT**  
Material \_\_\_\_\_ Volume used \_\_\_\_\_  
Method of installation \_\_\_\_\_  
Depth: placed from \_\_\_\_\_ ft to \_\_\_\_\_ ft.  
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other \_\_\_\_\_


## BAILING OR PUMPING TEST (specify one by circling)

**WELL TEST**  
Test rate 10 gpm Duration of test 2 hrs.  
Drawdown (water level during pumping) 65 ft.  
Measured from: ☒ top of casing ☐ ground level ☐ Other \_\_\_\_\_  
Static Level (depth to water) 65 ft. Date: \_\_\_\_\_  
Quality (clear, cloudy, taste, odor) Clear  
**PUMP**  
Type of pump \_\_\_\_\_ Capacity \_\_\_\_\_ gpm  
Pump set at \_\_\_\_\_ ft.  
Pump installed by \_\_\_\_\_  
**Pitless Device** ☐ Adapter ☐ Preassembled unit  
**Use of Well** Owner To Install Pump

## WELL LOG\*

| Show color, texture, hardness, and formation:<br>sandstone, shale, limestone, gravel, clay, sand | From       | To         |
|--------------------------------------------------------------------------------------------------|------------|------------|
|                                                                                                  | 0 ft       | ft         |
| <u>yellow clay soft</u>                                                                          |            | <u>15</u>  |
| <u>Blue clay soft</u>                                                                            | <u>15</u>  | <u>26</u>  |
| <u>Sand &amp; gravel</u>                                                                         | <u>26</u>  | <u>30</u>  |
| <u>Blue Shale</u>                                                                                | <u>30</u>  | <u>60</u>  |
| <u>Shale &amp; some gravel</u>                                                                   | <u>60</u>  | <u>95</u>  |
| <u>Sandstone</u>                                                                                 | <u>95</u>  | <u>105</u> |
| <u>water at</u>                                                                                  | <u>95</u>  |            |
| <u>Shale break</u>                                                                               | <u>105</u> | <u>113</u> |
|                                                                                                  |            |            |
|                                                                                                  |            |            |
|                                                                                                  |            |            |
|                                                                                                  |            |            |
|                                                                                                  |            |            |
|                                                                                                  |            |            |
|                                                                                                  |            |            |

## SKETCH SHOWING LOCATION



\* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM Regional Drilling & Dev.  
ADDRESS 196 Co. Rd 620  
CITY, STATE, ZIP West Salem OH

SIGNED Dennis Dietrich  
DATE 2-18-89  
ODH REGISTRATION NUMBER 1566

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy

143