

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224

691897

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number 105

COUNTY Miami TOWNSHIP UNION SECTION OF TOWNSHIP _____
OWNER David Antonidies PROPERTY ADDRESS 5860 Karns Rd
LOCATION OF PROPERTY 5860 Karns Rd, West Milton, O

CONSTRUCTION DETAILS

CASING

Casing Diameter 5 5/8 galv Length of Casing 29 ft

Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other

Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft Diameter _____ in.

Set between _____ ft and _____ ft Slot _____

GROUT

Material Concrete & Grout Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other

BAILING OR PUMPING TEST

(specify one by circling)

WELL TEST

Test rate 1 GPM gpm Duration of test _____ hrs.

Drawdown (water level during pumping) to 140 ft ft

Measured from: ☐ top of casing ☐ ground level ☐ Other

Static Level (depth to water) 19 ft ft Date: 9-30-91

Quality (clear, cloudy, taste, odor) _____

PUMP

Type of pump _____ Capacity _____ gpm

Pump set at _____ ft

Pump installed by _____

Pitless Device ☐ Adapter ☐ Preassembled unit

Use of Well _____

WELL LOG*

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand

From

To

Dirt & clay

0 ft

3 1/2 ft

Limestone

3 1/2

35

Grey rock

35

45

Yellowish Limestone

45

57

Bluish Grey rock

57

72

Blue Rock

72

117

Blue Clay & Rock

117

135

(very little blue clay)


Hard Blue Rock

135

140

SKETCH SHOWING LOCATION

Show distances well lies from numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM

ADDRESS

CITY, STATE, ZIP

LORIN C. SNELL
9313 WEST MARKLEY ROAD
LAURA, OHIO 45337
698-4222

SIGNED

DATE

ODH REGISTRATION NUMBER

L. C. Snell
9-30-91

319

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy