WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224

693709

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number _____

COUNTY Lucas TOWNSHIP Richfield SECTION OF TOWNSHIP _____

OWNER Robin Ford PROPERTY ADDRESS 5340 St. Rt. 295

LOCATION OF PROPERTY Rt#295, Berkey, Ohio 1/2 mile South of Syl.-Metamora

CONSTRUCTION DETAILS

CASING

Casing Diameter 5 in. Length of Casing 80 ft.

Type: ☐ Steel ☐ Galv. ☒ PVC ☐ Other _____

Joints: ☐ Threaded ☐ Welded ☒ Solvent ☐ Other _____

SCREEN

Type (wire wrapped, louvered, etc.) None Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

BAILING OR PUMPING TEST
(specify one by circling)

WELL TEST

Test rate 10 gpm Duration of test 3 hrs.

Drawdown (water level during pumping) 50 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 26 ft. Date: 12-23-91

Quality (clear, cloudy, taste, odor) clear

PUMP

Type of pump Submersible Capacity 12 gpm

Pump set at 78' ft.

Pump installed by Phil Bischoff Well Drilling

Pitless Device ☒ Adapter ☐ Preassembled unit

Use of Well private

WELL LOG*

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand	From	To
yellow clay*	0 ft.	12 ft.
gray clay	12	74
sand + gravel	74	77
black shale	77	80

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM Philip Bischoff Well Drilling SIGNED Philip Bischoff

ADDRESS 8388 Jetts DATE Dec. 30, 1991

CITY, STATE, ZIP Ottawa Lake, Mi 49267 ODH REGISTRATION NUMBER 735

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy