WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224

693713

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number _____

COUNTY Lucas TOWNSHIP Sylvania SECTION OF TOWNSHIP _____

OWNER Jerry Welch PROPERTY ADDRESS 5851 Flanders, Sylvania, Ohio

LOCATION OF PROPERTY 5851 Flanders 1/3 mile North of Alexis Rd.

CONSTRUCTION DETAILS

CASING

Casing Diameter 5 in. Length of Casing 84 ft.

Type: ☐ Steel ☐ Galv. ☒ PVC ☐ Other _____

Joints: ☐ Threaded ☐ Welded ☐ Solvent ☐ Other _____

SCREEN

Type (wire wrapped, louvered, etc.) NONE Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

BAILING OR PUMPING TEST
(specify one by circling)

WELL TEST

Test rate 20 gpm Duration of test 3 hrs.

Drawdown (water level during pumping) 62 ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 60 ft. Date: 12-30-91

Quality (clear, cloudy, taste, odor) clear

PUMP

Type of pump Submersible Capacity 12 gpm

Pump set at 75' ft.

Pump installed by Phil Bischoff

Pitless Device ☒ Adapter ☐ Preassembled unit

Use of Well single family

WELL LOG*

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand	From	To
yellow sand	0 ft.	32 ft.
gray silt	32	51
gray clay	51	73
gray limestone	73	110

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM Phil Bischoff Well Drlg. SIGNED Philip Bischoff

ADDRESS 8388 Jetts Rd. DATE 1-2-92

CITY, STATE, ZIP Ottawa Lake, Mi. 49267 ODH REGISTRATION NUMBER 735

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy