

WELL LOG AND DRILLING REPORT

695554

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224
(614) 265-6739

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number #W-27-89

COUNTY Wayne TOWNSHIP Chippewa SECTION/LOT NO. #2
(CIRCLE ONE)
OWNER/BUILDER Joe Berold 9571 Fry Rd. PROPERTY ADDRESS Foster Church Rd.
(CIRCLE ONE OR BOTH) LOCATION OF PROPERTY 18047 Racine Rd. Marshallville Rd. 44645
(ADDRESS OF WELL LOCATION A)

CONSTRUCTION DETAILS

CASING
Diameter 5" in. Length 25' ft. Wall Thickness 237 in.
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other
Joints: ☐ Threaded ☐ Welded ☐ Solvent ☐ Other

SCREEN
Type (wire wrapped, louvered, etc.) none Material
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of completion _____

GROUT
Material clay sand shale Volume used _____
Method of installation _____
Depth: placed from _____ ft. to 25' ft.

GRAVEL PACK
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well _____

PUMP
Type of pump owner Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____


WELL TEST
Bailing ☒ or Pumping ☐
Test rate 10 gpm Duration of test 3 hrs.
Drawdown 10 ft.

WELL LOG*
INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>yellow clay sand</u>	0 ft.	22 ft.
<u>broken sandstone</u>	22	25'
<u>sandstone</u>	25	58'
<u>dark shale</u>	58	65'
<u>shale</u>	65	85'
<u>sandstone</u>	85	97'
<u>shale</u>	97	135'
<u>sandstone</u>	135	142'
<u>shale</u>	142	149'
<u>sandstone</u>	149	165'
<u>dark shale</u>	165	187'
<u>fine sand stone</u>	187	198'
<u>coarse sandstone</u>	198	215'
<u>water 35' + 200'</u>		

Measured from: ☐ top of casing ☒ ground level ☐ Other
Static Level (depth to water) 130' ft. Date: Aug 18
Quality (clear, cloudy, taste, odor) clear
(Attach a copy of the pumping test record, per 1521.05, ORC)

SKETCH SHOWING LOCATION
Show distances well lies from numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.
DRILLING FIRM Steve Aldrich
ADDRESS 925 W. Turkeyfoot
CITY, STATE, ZIP Akron OH 44319

SIGNED Steve Aldrich
DATE 8/28/89
ODH REGISTRATION NUMBER 213

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Owner Copy Pink - Driller's Copy Green - Local Health Dept. Copy

573