

695555

Permit Number 99552

COUNTY Summit TOWNSHIP Bath SECTION/LOT NO. _____
(CIRCLE ONE)
OWNER M. J. Colarik BUILDER M. J. Colarik PROPERTY ADDRESS 847 Harrison Rd.
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 2330 Valley Wood Rd

CASING Diameter <u>5</u> in. Length <u>43</u> ft Wall Thickness <u>237</u> in. Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____ Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____ SCREEN Type (wire wrapped, louvered, etc.) _____ Material _____ Length _____ ft Diameter _____ in. Set between _____ ft and _____ ft Slot _____ ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____ Date of completion <u>Sept. 27 1989</u>	GROUT Material <u>clay sand & gravel</u> Volume used _____ Method of installation <u>driller</u> Depth: placed from _____ ft. to <u>42</u> ft. GRAVEL PACK Material _____ Volume used _____ Method of installation _____ Depth: placed from _____ ft. to _____ ft. Pitless Device ☐ Adapter ☐ Preassembled unit Use of Well <u>House</u>
--	--

WELL TEST

Type of pump _____ Capacity _____ ? gpm
Pump set at _____ ? ft.
Pump installed by _____

Bailing ☒ or Pumping ☐
 Test rate 10 gpm Duration of test 3 hrs.
 Drawdown 15' ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 33 ft. Date: 9/27/89
 Quality (clear, cloudy, taste, odor) clear.
 (Attach a copy of the pumping test record, per 1521.05, ORC)

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
------	----

Yellow Clay & gravel	0 ft	20' ft
sand & gravel.	20	41
shale	41'	54'
sandy shale	54	62
shale	62	68'

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

W

1

S

DNR 7802.88

DRILLING FIRM Steve Chapman SIGNED Steve Chapman
ADDRESS 925 W Turkeyfoot Lake Rd DATE 9/27/89
CITY, STATE, ZIP Abram OH 444319 ODH REGISTRATION NUMBER 213

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy