

WELL LOG AND DRILLING REPORT

696247

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224
(614) 265-6739

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number _____

COUNTY Miami TOWNSHIP Monroe SECTION/LOT NO. _____
(CIRCLE ONE)
OWNER/BUILDER Tom Sager PROPERTY ADDRESS 905 Shoop Rd.
(CIRCLE ONE OR BOTH)
LOCATION OF PROPERTY TRACK # 2 LOT # 13501 Tipp City OH 45371
(ADDRESS OF WELL LOCATION)

CONSTRUCTION DETAILS

CASING 5 5/8 in. Length 85 ft. Wall Thickness 0.32 in.
Type: ☐ Steel ☒ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____
SCREEN
Type (wire wrapped, louvered, etc.) Perf Material Gal.
Length 3 ft. Diameter 5 5/8 in.
Set between 82 ft. and 85 ft. Slot _____
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of completion 8/17/89

GROUT
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
GRAVEL PACK
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well House

PUMP
Type of pump D Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

WELL TEST
Bailing ☒ or Pumping ☐
Test rate 15 gpm Duration of test 1 hrs.
Drawdown _____ ft.
Measured from: ☐ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 30 ft. Date: _____
Quality (clear, cloudy, taste, odor) CLEAR
(Attach a copy of the pumping test record, per 1521.05, ORC)

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.


Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL	0 ft.	1 ft.
CLAY	1	4
GRAVEL	4	6
CLAY	6	30
GRAVEL	30	32
CLAY	32	65
GRAVEL	65	66
CLAY	66	80
SAND & GRAVEL	80	85

SKETCH SHOWING LOCATION

Show distances well lies from numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form

DRILLING FIRM W. Barker
ADDRESS 1085 School Rd.
CITY, STATE, ZIP New Charles OH 45344

SIGNED Joseph Barker
DATE 8/29/89
ODH REGISTRATION NUMBER 42

DNR 7802.88

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy