

697553

Permit Number Irrigation


COUNTY Warren TOWNSHIP Monroe-Turtle Creek SECTION/LOT NO. _____
(CIRCLE ONE)
OWNER/BUILDER SHAKER LAND FARMS PROPERTY ADDRESS 146 Concord Dr. Lebanon
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION &)
LOCATION OF PROPERTY Southwest of Lebanon Correctional Institute On 45036

CASING Diameter <u>16</u> in. Length <u>77</u> ft. Wall Thickness <u>.50</u> in. Type: ☐ Steel ☐ Galv. ☒ PVC ☐ Other _____ Joints: ☐ Threaded ☐ Welded ☒ Solvent ☐ Other _____ SCREEN Type (wire wrapped, louvered, etc.) <u>SLOT</u> Material <u>PVC</u> Length <u>20</u> ft. Diameter <u>1/4 IN.</u> in. Set between <u>57</u> ft. and <u>77</u> ft. Slot <u>060</u> ☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other <u>Bucket</u> Date of completion <u>3-3-89</u>	GROUT Material <u>Bentonite</u> Volume used <u>20 bag on top of Case</u> Method of installation <u>Pour from bag</u> Depth: placed from <u>28</u> ft. to <u>0</u> ft. GRAVEL PACK Material <u>#12 IN.</u> Volume used <u>21 Ton</u> Method of installation <u>Pour</u> Depth: placed from <u>77</u> ft. to <u>28</u> ft. Pitless Device ☐ Adapter ☐ Preassembled unit Use of Well <u>IRRIGATION</u>
--	---

Bailing ☐ or Pumping ☒
 Test rate 300 gpm Duration of test 4 hrs.
 Drawdown none ft.
 Measured from: ☒ top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) 19 ft. Date: 9/13/89
 Quality (clear, cloudy, taste, odor) Clear
 (Attach a copy of the pumping test record, per 1521.05, ORC)

Fill dirt	0 ft.	5 ft.
Gray clay	5	30
Coarse sand & water	30	75
Hard blue clay	75	77
Penetration stopped due to rock on bottom		

Show distances well lies from numbered state highways, street intersections, county roads, etc.



SIGNED John R. [Signature]
DATE 6-13-89 6-6-89
ODH REGISTRATION NUMBER #1699

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy