

702006

Permit Number 103436

COUNTY Stark TOWNSHIP Lexington SECTION/LOT NO. 7
(CIRCLE ONE)
☒ OWNER Tom Tenney ☐ BUILDER _____ PROPERTY ADDRESS 160 N. Atwater Ave, Lima, OH 44026
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION ▲)
LOCATION OF PROPERTY Lima, OH

CASING		GROUT	
Diameter <u>5"</u> in.	Length <u>146'</u> ft.	Wall Thickness _____ in.	Material <u>Q Gel + Hopslug</u> Volume used <u>3 bags</u>
Type: ☒ Steel	☐ Galv.	☐ PVC	☐ Other _____
Method of installation _____	Method of installation <u>Gravity</u>	Depth: placed from _____ ft. to _____ ft.	Depth: placed from _____ ft. to _____ ft.
Joints: ☒ Threaded	☐ Welded	☐ Solvent	☐ Other _____
SCREEN		GRAVEL PACK	
Type (wire wrapped, louvered, etc.) _____	Material _____	Material _____	Volume used _____
Length _____ ft.	Diameter _____ in.	Method of installation _____	Method of installation _____
Set between _____ ft. and _____ ft.	Slot _____	Depth: placed from _____ ft. to _____ ft.	Depth: placed from _____ ft. to _____ ft.
☒ Rotary	☐ Cable	☐ Augered	☐ Driven
☐ Dug	☐ Other _____	Pitless Device ☒ Adapter	☐ Preassembled unit
Date of completion _____	Use of Well <u>Domestic</u>		

Type of pump submersible Capacity 10 gpm
Pump set at _____ ft.
Pump installed by _____

Bailing ☐ or Pumping ☒ *an test*
 Test rate 20 gpm Duration of test 41 hrs.
 Drawdown _____ ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 11 ft. Date: _____
 Quality clear cloudy, taste, odor _____
 (Attach a copy of the pumping test record, per 1521.05, ORC)

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

[illegible]

Show distances well lies from numbered state highways, street intersections, county roads, etc.

abandoned N 6" well 80' deep
sealed w hole plug to surface

* If additional space is needed to complete well log, use next consecutively numbered form

DNR 7802.68

DRILLING FIRM Langdon Chilling
ADDRESS 3160 Beechwood Ave
CITY, STATE, ZIP Alliance Oh 44601

SIGNED W. E. Lyndson
DATE 9-29-89
ODH REGISTRATION NUMBER 504

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy