WELL LOG AND DRILLING REPORT

702847

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224
(614) 265-6739

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number _____

COUNTY Montgomery TOWNSHIP Miami SECTION/LOT NO. _____ (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) Bob Anderson PROPERTY ADDRESS 7414 Jamaica Rd (ADDRESS OF WELL LOCATION ▲)

LOCATION OF PROPERTY Between 725 & L. Msbg. Rd.

CONSTRUCTION DETAILS

CASING
Diameter 6 in. Length _____ ft. Wall Thickness _____ in.
Type: ☐ Steel ☒ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____

SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of completion June 27, 1995

GROUT
Material Cement Volume used _____
Method of installation Dry
Depth: placed from 38" ft. to 48" ft.

GRAVEL PACK
Material None Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.

Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Home

PUMP
Type of pump 3/4 Hsp. Capacity 12 gpm
Pump set at 150 ft.
Pump installed by Agua Springs

WELL TEST
Bailing ☒ or Pumping ☐
Test rate 5 gpm Duration of test 10 hrs.
Drawdown 3 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 55 ft. Date: June 26
Quality (clear, cloudy, taste, odor) Clear
(Attach a copy of the pumping test record, per 1521.05, ORC)

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0 ft.	3 ft.
Brown Clay	3	5
Gray Clay	5	25
Gravel + Brown Clay	25	40
Shale + Sand	40	50
Sand + Gravel - Water	50	60
Water - Muddy w/ gravel not clear		
Brown Clay + Gravel	60	102
Brown Clay + Sand	102	164
Gravel + Water	165	

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



DNR 7802.88

* If additional space is needed to complete well log, use next consecutively numbered form

DRILLING FIRM Agua Springs Well Drilling **SIGNED** David King
ADDRESS 10733 Hemple Rd. **DATE** 4-23-96
CITY, STATE, ZIP Farmersville Oh 45325 **ODH REGISTRATION NUMBER** 2095

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy