WELL LOG AND DRILLING REPORT

702942

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224
(614) 265-6739

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number 35

COUNTY Henry TOWNSHIP Napoleon SECTION LOT NO. 25 (CIRCLE ONE)

OWNER/BUILDER John and Pam Riedeman (CIRCLE ONE OR BOTH) PROPERTY ADDRESS SW Corner (1/4) of Section 25 (ADDRESS OF WELL LOCATION ▲)

LOCATION OF PROPERTY N-232 - Rd 14 Napoleon, Ohio

CONSTRUCTION DETAILS

CASING
Diameter 6 in. Length 53 ft. Wall Thickness .258 in.
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other

SCREEN
Type (wire wrapped) louvered, etc.) Material SS
Length 5 ft. Diameter 5 in.
Set between 53 ft. and 57 ft. Slot .006
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of completion 6-26-91

GROUT
Material Volume used
Method of installation
Depth: placed from ft. to ft.

GRAVEL PACK
Material Volume used
Method of installation
Depth: placed from ft. to ft.

Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well Home

PUMP

Type of pump Sub Capacity 5 gpm
Pump set at 47 ft.
Pump installed by Larry Rupp

WELL TEST

Bailing ☒ or Pumping ☐
Test rate 8 gpm Duration of test 2½ hrs.
Drawdown 9 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other
Static Level (depth to water) 24 ft. Date: 6-25-91
Quality (clear, cloudy, taste, odor) Clear
(Attach a copy of the pumping test record, per 1521.05, ORC)

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0 ft.	2 ft.
Yellow Sand	3	9
Yellow Clay	10	18
Gray Clay	19	29
Gray Clay & Gravel	30	49
Hard Pan & Gravel	50	52
Fine Sand & Water	53	57

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form

DNR 7802.88

DRILLING FIRM Larry Rupp & Stanley Frey
ADDRESS R1 Box 98
CITY, STATE, ZIP Stryker Ohio 43557

SIGNED Larry Rupp
DATE 6-28-91
ODH REGISTRATION NUMBER 1019

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy