

706145

Permit Number _____

COUNTY Greene TOWNSHIP Xenia SECTION/LOT NO. —
(CIRCLE ONE)
OWNER/BUILDER Harry Rose PROPERTY ADDRESS 700 Hawkins School House Rd
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY West of Fairground Rd.

CASING		GROUT	
Diameter <u>5 5/8</u> in.	Length <u>54</u> ft.	Material <u>Drill Cutting</u>	Volume used <u> </u>
Type: ☐ Steel ☒ Galv. ☐ PVC ☐ Other <u> </u>	Wall Thickness <u>142</u> in.	Method of installation <u>dry pack</u>	
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other <u> </u>		Depth: placed from <u>50</u> ft. to <u>54</u> ft.	
SCREEN		GRAVEL PACK	
Type (wire wrapped, louvered, etc.) <u> </u>	Material <u> </u>	Material <u> </u>	Volume used <u> </u>
Length <u> </u> ft.	Diameter <u> </u> in.	Method of installation <u> </u>	
Set between <u> </u> ft. and <u> </u> ft.	Slot <u> </u>	Depth: placed from <u> </u> ft. to <u> </u> ft.	
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other <u> </u>		Pitless Device ☒ Adapter ☐ Preassembled unit	
Date of completion <u>12/15/90</u>		Use of Well <u>Household</u>	

WELL TEST

Type of pump submersible Capacity 10 gpm
Pump set at 100 ft. ft.
Pump installed by homeowner

Bailing ☒ or Pumping ☐
 Test rate _____ gpm Duration of test 3 hrs.
 Drawdown total ft.

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

Topsoil	0 ft	2 ft
Dry sand & gravel	2	28
Clay	28	36
gravel & sand	36	54
shale	54	110

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

N

W

9

* If additional space is needed to complete well log, use next consecutively numbered form.

DRILLING FIRM Longwell Drilling
ADDRESS 2898 Blackhawk Rd.
CITY, STATE, ZIP Kettering Oh. 45420

SIGNED [Signature]
DATE 12/13/90
ODH REGISTRATION NUMBER 749

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy