

706146

Permit Number _____

COUNTY Greene TOWNSHIP Beavercreek SECTION/LOT NO. 3972
(CIRCLE ONE)
OWNER/BUILDER Richard Calcutta PROPERTY ADDRESS North of Dayton-Xenia Rd.
(CIRCLE ONE OR BOTH)
LOCATION OF PROPERTY North of Dayton-Xenia Rd.

CASING 5/8 in. Length _____ ft. Wall Thickness -142 in.
Type: ☐ Steel ☒ Galv. ☐ PVC ☐ Other _____
Joints: ☐ Threaded ☒ Welded ☐ Solvent ☐ Other _____

SCREEN
Type (wire wrapped, louvered, etc.) W.W. Material A - S
Length 3 ft. Diameter 4 in.
Set between _____ ft. and _____ ft. Slot _____
☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of completion 12/20/90

GROUT Material Benscal Volume used 120 #
Method of installation dry pack
Depth: placed from 70 ft. to 100 ft.

GRAVEL PACK
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.

Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well household

PUMP

Type of pump Submersible Capacity 10 gpm
Pump set at 85 ft.
Pump installed by Lotto Well Drilling

WELL TEST

Bailing ☒ or Pumping ☐
 Test rate 40 gpm Duration of test 2 hrs.
 Drawdown 1 ft.
 Measured from: ☒ top of casing ☐ ground level ☐ Other
 Static Level (depth to water) 35 ft. Date: 12/20/90
 Quality (clear, cloudy, taste, odor) clear
 (Attach a copy of the pumping test record, per 1521.05, ORC)

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

[illegible]

SKETCH SHOWING LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

A hand-drawn map showing the intersection of Dayton Xenia Rd. and South Ave. Rd. A circle is drawn around the intersection, with an 'X' inside. A line points to the circle with the label '100 yds'. The map is oriented with N at the top, S at the bottom, W on the left, and E on the right.

* If additional space is needed to complete well log, use next consecutively numbered form

DRILLING FIRM Lotts Well Drilling
ADDRESS 2848 Blackhawk Rd.
CITY, STATE, ZIP Kettering Ohio 45420

SIGNED [Signature]
DATE 12/20/90
OPH REGISTRATION NUMBER 749

/DNR 7802.88

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy