

WELL LOG AND DRILLING REPORT

707875

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1939 Fountain Square Drive
Columbus, Ohio 43224
(614) 265-6739

TYPE OR USE PEN
SELF-TRANSCRIBING
PRESS HARD!

Permit Number 698-90

COUNTY Hancock Co. TOWNSHIP Armanda SECTION 27 LOT NO. 37
(CIRCLE ONE)
OWNER/BUILDER Richard R Kuengli PROPERTY ADDRESS 17787 St. Blanche
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION)
LOCATION OF PROPERTY app. 100' North of Corp line on St. Bl. 37

CONSTRUCTION DETAILS

CASING
Diameter 6 in. Length 28 1/2 ft. Wall Thickness .142 in.
Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other
SCREEN
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in.
Set between _____ ft. and _____ ft. Slot _____
☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other
Date of completion 7-3-90
GROUT
Material Anhydrous Cement Volume used _____
Method of installation Thumping
Depth: placed from 26 1/2 ft. to Surface ft.
GRAVEL PACK
Material _____ Volume used _____
Method of installation _____
Depth: placed from _____ ft. to _____ ft.
Pitless Device ☐ Adapter ☐ Preassembled unit
Use of Well Private Drinking

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.


	From	To
<u>Brown Clay</u>	<u>0 ft.</u>	<u>10 ft.</u>
<u>Gray Clay</u>	<u>10</u>	<u>18</u>
<u>Gray Sand Clay</u>	<u>18</u>	<u>24</u>
<u>Shell Rock</u>	<u>24</u>	<u>26</u>
<u>Line Stone</u>	<u>24</u>	<u>40</u>
<u>Water 29</u>		
<u>34</u>		
<u>39</u>		

WELL TEST

Bailing ☐ or Pumping ☒
Test rate 3/8 gpm Duration of test _____ hrs.
Drawdown _____ ft.
Measured from: ☒ Top of casing ☐ ground level ☐ Other
Static Level (depth to water) 22 ft. Date: 7-3-90
Quality (clear, cloudy, taste, odor) _____
(Attach a copy of the pumping test record, per 1521.05, ORC)

SKETCH SHOWING LOCATION

Show distances well lies from numbered
state highways, street intersections, county roads, etc.



* If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.88

DRILLING FIRM Stemmer Well Drilling SIGNED Janey Stemmer
ADDRESS P.O. Box 37 DATE 7-3-90
CITY, STATE, ZIP Shiloh, OH 45847 ODH REGISTRATION NUMBER 17269

Completion of this form is required by 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's Copy Pink - Driller's Copy Green - Local Health Dept. Copy