

717288

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number

TOWNSHIP

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS

(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

CONSTRUCTION DETAILS

CASING		Borehole Diameter		in.	
[1] Diameter	S	in.	Length	120	ft.
[2] Diameter		in.	Length		ft.
Type:	[1] Steel	[1] Galv.	[1] PVC	[1]	Wall Thickness
	[2] Steel	[2] Galv.	[2] PVC	[2] Other	
Joints:	[1] Threaded	[1] Welded	[1] Solvent	[1]	
	[2] Threaded	[2] Welded	[2] Solvent	[2] Other	
Liner:	Length	Type	Wall Thickness		
SCREEN					
Type (wire wrapped, louvered, etc.)			Material		
Length		ft.	Diameter		
Set between		ft. and		ft.	Slot

GROUT		Material		Clay	
in.	Method of installation	Volume used		900	
Depth: placed from		ft. to			
GRAVEL PACK (Filter Pack)					
Material		Volume used			
Method of installation		ft. to			
Depth: placed from		ft. to			
Pitless Device	[X] Adapter	[] Preassembled unit			
Use of Well					
in.	[] Rotary	[X] Cable	[] Augered	[] Driven	[] Dug
Date of Completion					

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
------	----

Drift	0	5
Sand Rock	5	10
Hard Brown Stone	10	20
Grey Rock	20	40
Grey Shale Clay	40	60
LITTLE Coal Clay SAND	60	75
Grey SAND Stone	75	100
Grey SAND	100	130
Grey Sand	130	145
Shaly Clay	145	170
Clay Shale	170	190
Grey Rock	190	230
SAND SHALE	230	260
Grey Rock	260	275
Indian Stone	275	300
WATER AT 275		

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other.

Test rate _____ gpm Duration of test _____ hrs.

Drawdown _____ ft.

Measured from: ☐ top of casing ☐ ground level ☐ Other

Static Level (depth to water) _____ ft. Date: _____

Quality (clear, cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump 1 1/2" 306 Capacity 5 gpm
Pump set at 306 ft.
Pump installed by Miller & Son

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

N

A hand-drawn sketch map, likely a field sketch, showing a site layout. At the top, a horizontal line is labeled '7.7'. Below this line, on the left, is the label '664 S'. To the far left, the letter 'W' indicates a direction. On the right side, there is a label '92 S E'. In the lower right area, the words 'Hammer' and 'Lost Hollow' are written, with 'S' and 'E' indicating directions. At the bottom left, the name '(Tom Miller)' is written. The sketch consists of simple lines representing boundaries or paths.

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm 1. Wm. Newell Driller
Address 3027 1 my R.D. Logans
City, State, Zip 43138

Signed Kong M. M.
Date 7-0-91
ODH Registration Number 1468

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy