

WELL LOG AND DRILLING REPORT

717292

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 92-035

COUNTY FAIRFIELD

TOWNSHIP Greenfield

SECTION/LOT No. _____
(CIRCLE ONE)

OWNER/BUILDER Orval Spangler
(CIRCLE ONE OR BOTH)

PROPERTY ADDRESS 1141 Goonpath R.D. NW
(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY _____

CONSTRUCTION DETAILS

CASING		Borehole Diameter _____ in.		GROUT	
1 Diameter <u>5"</u> in.	Length <u>60</u> ft.	Wall Thickness _____ in.	Material <u>Hot E Plug</u>	Volume used <u>200</u>	
2 Diameter _____ in.	Length _____ ft.	Wall Thickness _____ in.	Method of installation <u>Pour</u>		
Type: 1 Steel 2 Galv. 3 PVC		1 2 Other _____	Depth: placed from _____ ft. to _____ ft.		
Joints: 1 Threaded 2 Welded 3 Solvent		1 2 Other _____	GRAVEL PACK (Filter Pack)		
Liner: Length _____ Type _____	Wall Thickness _____ in.	Depth: placed from _____ ft. to _____ ft.	Material _____	Volume used _____	
SCREEN		Type (wire wrapped, louvered, etc.) _____		Material _____	
Length _____ ft.		Diameter _____ in.		Set between _____ ft. and _____ ft. Slot _____	
				Date of Completion _____	

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Red</u>	<u>0</u>	<u>5</u>
<u>Brown Sand</u>	<u>5</u>	<u>10</u>
<u>Brown Sand gravel</u>	<u>10</u>	<u>20</u>
<u>Red Sand</u>	<u>20</u>	<u>40</u>
<u>Gray SHALE Clay Sandy</u>	<u>40</u>	<u>60</u>
<u>Gray Stone</u>	<u>60</u>	<u>65</u>
<u>RED Sand</u>	<u>65</u>	<u>80</u>
<u>Sand Water at</u>	<u>80</u>	<u>8'6"</u>

WELL TEST


☐ Bailing ☐ Pumping* ☐ Other _____
 Test rate 20 gpm Duration of test _____ hrs.
 Drawdown 20 ft.
 Measured from: ☐ top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) _____ ft. Date: _____
 Quality (clear, cloudy, taste, odor) _____
 *(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Deep Well Capacity 10 gpm
 Pump set at 10 ft off bottom ft.
 Pump installed by Miller Drilling

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



RECEIVED

2002 MAR 25

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Miller Drilling
Address 30221 Map R.D.
City, State, Zip Loyan OH 43131

Signed Thomas Miller
Date 2-10-92
ODH Registration Number 1468

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy