

WELL LOG AND DRILLING REPORT

720090

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 1012-92

COUNTY MORROW TOWNSHIP HARMONY SECTION/LOT No. 191
(CHOOSE ONE OR BOTH)
OWNER/BUILDER FRED MCGILL PROPERTY ADDRESS 5385 CR 191
(ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 5385 C.R. 191

CONSTRUCTION DETAILS

CASING Borehole Diameter 5 in.
① Diameter 5 1/2 in. Length 8 ft. Wall Thickness 1/2 in. Material GROUT Volume used 15 POUNDS
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation AROUND CASING
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☐ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Use of Well ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between _____ ft. and _____ ft. Slot _____ Date of Completion 6-26-92

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

TOP SOIL
GREY SHALE
BED ROCK

From	To
0	1
1	175
175	201

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 5 gpm Duration of test 1 1/2 hrs.
Drawdown NONE ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 40 ft. Date: 6-25-92
Quality (clear, cloudy, taste, odor) _____
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump _____ Capacity _____ gpm
Pump set at _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Earl W. Pinkerton Signed Earl W. Pinkerton
Address 179 CARDINGTON 43315 Date 6-28-92
City, State, Zip OH IO ODH Registration Number 1237

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy