

721560

Permit Number W-41-90

CONSTRUCTION DETAILS

CASING		Borehole Diameter _____ in.		GROUT	
① Diameter	5 1/2 in.	Length	35 ft.	Wall Thickness	1 1/2 in.
② Diameter	_____ in.	Length	_____ ft.	Wall Thickness	_____ in.
Type:	☒ Steel	☐ Galv.	☐ PVC	☐ Other	_____
Joints:	☒ Threaded	☐ Welded	☐ Solvent	☐ Other	_____
Liner:	Length _____	Type _____	Wall Thickness _____ in.	Depth: placed from _____	ft. to _____ ft.
SCREEN				GRAVEL PACK (Filter Pack)	
Type (wire wrapped, louvered, etc.) _____				Material _____	
Length _____ ft.				Volume used _____	
Diameter _____ in.				Method of installation _____	
Set between _____ ft. and _____ ft.				Depth: placed from _____	
Slot _____				ft. to _____ ft.	
Date of Completion _____				Pitless Device ☒ Adapter ☐ Preassembled unit	
Use of Well _____				Rotary ☐ Cable ☒ Augered ☐ Driven ☐ Dug ☐ Other ☐	

WELL LOG*

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

DRIFT	0	4
BROWN CLAY	4	12
GRAY MUD	12	34
GRAY SANDSTONE	34	35
GRAY SHALE	35	49
WATER SAND	49	55
GRAY SHALE	55	70

WATER AT 50'

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____

Test rate 10 gpm Duration of test 1 hrs.

Drawdown 5' ft.

Measured from: ☐ top of casing ☒ ground level ☐ Other _____

Static Level (depth to water) 35 ft. Date: 2-1-91

Quality (clear, cloudy, taste, odor) CLEAR


*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Capacity _____ gpm
Pump set at 60 _____ ft.
Pump installed by _____

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm REY DRILLING Signed Rex Donelson
Address 1080 Co Rd 2075 RD4 Date 2-1-91