

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

725245

Permit Number

83-94

COUNTY Hocking

TOWNSHIP Starr

SECTION/LOT No.
(CIRCLE ONE)

OWNER/BUILDER
(CIRCLE ONE OR BOTH)

Dan Carson

PROPERTY ADDRESS

19190 Loomis Rd.

(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

19190 Loomis Rd.

CONSTRUCTION DETAILS

CASING

① Diameter 5 1/2 in. Length 250 ft. Wall Thickness 1/4 in.

② Diameter _____ in. Length _____ ft. Wall Thickness _____ in.

Type: ① Steel ① Galv. ① PVC ① _____
② _____ ② _____ ② _____ ② _____

Joints: ① Threaded ① Welded ① Solvent ① _____
② _____ ② _____ ② _____ ② _____

Liner: Length ✓ Type _____ Wall Thickness _____ in.

SCREEN

Type (wire wrapped, louvered, etc.) ✓ Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material Benseal Volume used 4 bags

Method of installation down annulus

Depth: placed from 0 ft. to 250 ft.

GRAVEL PACK (Filter Pack)

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

Pitless Device

☒ Adapter

☐ Preassembled unit

Use of Well

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

Date of Completion 9

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Surface	0	15
Shale (Gray)	15	68
Coal Blossom	68	73
Coal	73	75
Shale (gray)	75	135
Shale white sandy	135	150
white shale Coal	150	151
white shale	151	180
Shale (Gray)	180	210
Sand gray	210	229
Coal	229	232
Sand gray	232	250
Shale gray	250	426
Shale black	426	447
Lime white	447	475
Shale gray	475	572
Indn sand	572	589
		T.D.

WELL TEST

☒ Bailing ☒ Pumping* ☐ Other _____

Test rate 5 gpm Duration of test 2 hrs.

Drawdown 800 700' ft.

Measured from: ☒ Top of casing ☐ ground level ☐ Other _____

Static Level (depth to water) 300 ft. Date: 9-23-94

Quality (clear, cloudy, taste, odor) 1.07

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Submersible Capacity 10 gpm

Pump set at 500 ft.

Pump installed by Lee NoTestine

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N
Building
X
well
E
Loomis Rd.

*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm

NoTestine

Signed

Lee NoTestine

Address

11097 Frasure Helber Rd.

Date

9-24-94

City, State, Zip

Logan Oh. 43130

ODH Registration Number

11

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN

Blue - Customer's copy Pink - Driller's copy Green - Local Health

5428