

WELL LOG AND DRILLING REPORT

727602

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 90-349

COUNTY Licking TOWNSHIP Lima SECTION/LOT No. Reynoldsburg 43068
(CIRCLE ONE)
OWNER/BUILDER Dr. Forrest Fleweller PROPERTY ADDRESS 85 Charward Dr SW
(CIRCLE ONE OR BOTH)
LOCATION OF PROPERTY South of RT 16 East of Taylor at Subaquatics South to Charward
(ADDRESS OF WELL LOCATION A)

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in. **GROUT**
① Diameter 5 in. Length 175 ft. Wall Thickness 0.25 in. Material _____ Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____ Depth: placed from _____ ft. to _____ ft.
Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____ **GRAVEL PACK** (Filter Pack)
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____ Use of Well House
Length 2 ft. Perforated Diameter _____ in. ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Set between 171 ft. and 173 ft. Slot Drilled Date of Completion 1-10-91

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
0	170
170	175

Clay
Sand
Water in Sand

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 1.5 gpm Duration of test 2 hrs.
Drawdown 1.5 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 100 ft. Date: 12-29-90
Quality (clear) cloudy, taste, odor)
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Subm 3/4 HP Capacity 10 gpm
Pump set at 140 ft.
Pump installed by Robert Davis

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Robert Davis Well Drilling Signed Robert Davis
Address 6857 Palmer Rd SW Date Sept. 11-91
City, State, Zip Millersport Ohio 43046 ODH Registration Number 631