

WELL LOG AND DRILLING REPORT

730225

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number

COUNTY Williams TOWNSHIP Center SECTION/LOT No. 29
(CIRCLE ONE)
OWNER/BUILDER Vern Coi PROPERTY ADDRESS 08523 45-6
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY 1/2 mile west cord 9 North Side US-6

CONSTRUCTION DETAILS

CASING Borehole Diameter 7 1/8 in.
① Diameter 5 in. Length 86 ft. Wall Thickness 1/4 in. Material Ben Seal Volume used 100
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ① Steel ① Galv. ② PVC ① _____ ② Other _____
Joints: ① Threaded ① Welded ② Solvent ① _____ ② Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from 0 ft. to 800 ft.
SCREEN Material PVC
Type (wire wrapped, louvered, etc.) _____
Length 4 ft. Diameter 5 in.
Set between 86 ft. and 90 ft. Slot 30
GROUT Material Gr. 75 Volume used 250
Method of installation _____
Depth: placed from 84 ft. to 92 ft.
Pitless Device ☒ Adapter ☐ Preassembled unit
Use of Well ☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion _____

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Drive Way - Top Soil	0	1
Yellow Brown Clay	1	12
Grey Clay	12	35
Grey Clay Gravel Hardpan	35	48
fine Sand	48	51
Grey Clay + Gravel	51	82
Sand + Gravel	82	92

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 40 + gpm Duration of test 1 hrs.
Drawdown _____ ft.
Measured from: ☒ top of casing ☐ ground level ☐ Other _____
Static Level (depth to water) 32 ft. Date: _____
Quality (clear, cloudy, taste, odor) _____
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub Aerator Capacity 12 gpm
Pump set at 40 ft.
Pump installed by Gilbert W/D

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Gilbert W/D Signed David Smith
Address 10-965 SR-34 Date _____
City, State, Zip Bryan Ohio 43506 ODH Registration Number 55

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

395