

735038

Permit Number W-344-92

LOCATION OF PROPERTY 2 mi. S. of H. R. 301 on west side of road. Sec 18

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.

① Diameter 5" in. Length 36 ft. Wall Thickness 1/4 in.

② Diameter _____ in. Length _____ ft. Wall Thickness _____ in.

Type: ☒ Steel ☐ Galv. ☐ PVC ☐ Other _____

② ☐ ☐ Galv. ☐ PVC ☐ Other _____

Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____

② ☐ ☐ Welded ☐ Solvent ☐ Other _____

Liner: Length _____ Type _____ Wall Thickness _____ in.

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material Bentonite Volume used 100 ^{qt}

Method of installation dry mix packed

Depth: placed from _____ ft. to 34 ft.

GRAVEL PACK (Filter Pack)

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

Pitless Device ☐ Adapter ☐ Preassembled unit

Use of Well Residential

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____

Date of Completion 10-12-82

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

yellow, Clay	0	17
blue Clay	17	28
blue Shale	28	75

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 20 gpm Duration of test 5 hrs.
 Drawdown 3 ft.
 Measured from: ☐ top of casing ☒ ground level ☐ Other _____
 Static Level (depth to water) 25 ft. Date: 10-12-92
 Quality (clear, cloudy, taste, odor) Clear

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Sub. Capacity 10 gpm
Pump set at ~~20~~ 50 ft.
Pump installed by Driller

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

A hand-drawn map showing the intersection of W. Salmon Rd. and W. Salmon R. The map is oriented with North (N) at the top, South (S) at the bottom, East (E) to the right, and West (W) to the left. A vertical line represents W. Salmon R., with the number '301' written near the top. A horizontal line represents W. Salmon Rd. A point is marked on the vertical line with an arrow pointing to it from the left, and another point is marked on the horizontal line with an arrow pointing to it from the left.

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm West Salem Drilling Signed Virgil W. Smith
Address Box 18 Date 10-12-92
City, State, Zip West Salem, OH 44397 ODH Registration Number 111

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy