TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Divison of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number _____

COUNTY Licking TOWNSHIP Newton SECTION/LOT No. TOWNSHIP 3 RANGE E-12 (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH) Linda Christman PROPERTY ADDRESS 4751 Dry Creek Rd. Newark O (ADDRESS OF WELL LOCATION)

LOCATION OF PROPERTY 1 mile West of State Route 13 - On Dry Creek

CONSTRUCTION DETAILS

CASING Borehole Diameter 7" in.

[1] Diameter 7" in. Length 116 ft. Wall Thickness 3/16 in.

[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in.

Type: [1] [2] Steel; [1] [2] Galv.; [1] [2] PVC; [1] [2] Other 7" Shoe

Joints: [1] [2] Threaded; [1] [2] Welded; [1] [2] Solvent; [1] [2] Other _____

Liner: Length _____ Type _____ Wall Thickness _____ in.

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft. Diameter _____ in.

Set between _____ ft. and _____ ft. Slot _____

GROUT

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

GRAVEL PACK (Filter Pack)

Material _____ Volume used _____

Method of installation _____

Depth: placed from _____ ft. to _____ ft.

Pitless Device [X] Adapter [ ] Preassembled unit

Use of Well _____

[ ] Rotary [X] Cable [ ] Augered [ ] Driven [ ] Dug [ ] Other _____

Date of Completion 9/6/91

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Soil	0	3
Yellow Sand	3	70
Grey Sand	70	76
Gravel	76	78
Sand	78	117
Total depth	117	
Water @ 115'-117		

WELL TEST

[X] Bailing [ ] Pumping* [ ] Other _____

Test rate 15- gpm Duration of test 24 hrs.

Drawdown _____ ft.

Measured from: [ ] top of casing [X] ground level [ ] Other _____

Static Level (depth to water) 65 ft. Date: 9/4/91

Quality (clear, cloudy, taste, odor) _____

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Ruth berry Capacity 9 gpm

Pump set at 90' ft.

Pump installed by Ralph Morgan

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Morgan Drilling

Address 9265 Blackhorse Rd.

City, State, Zip Somerset, O 43783

Signed Ralph Morgan

Date Sept 5, 1991

ODH Registration Number 1430

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy