

WELL LOG AND DRILLING REPORT

735129

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 34-91

COUNTY Perry TOWNSHIP Reading SECTION/LOT No. 3
(CIRCLE ONE)
OWNER/BUILDER Pian Emmert PROPERTY ADDRESS T Road 70
(CIRCLE ONE OR BOTH) (ADDRESS OF WELL LOCATION A)
LOCATION OF PROPERTY 1/2 mile east of State Route 13 on T 70

CONSTRUCTION DETAILS

CASING Borehole Diameter _____ in.
① Diameter 1 in. Length 39 ft. Wall Thickness 1/4" in. Material _____ Volume used _____
② Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____
Type: ① Steel ① Galv. ① PVC ① _____
Joints: ① Threaded ① Welded ① Solvent ② Other _____
Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.
SCREEN Pitless Device ☒ Adapter ☐ Preassembled unit
Type (wire wrapped, louvered, etc.) _____ Material _____
Length _____ ft. Diameter _____ in. Use of Well Domestic
Set between _____ ft. and _____ ft. Slot _____ ☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other _____
Date of Completion 9/21/91

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Yellow Clay</u>	<u>0</u>	<u>16</u>
<u>White Shale</u>	<u>16</u>	<u>19</u>
<u>White shale & Coal</u>	<u>19</u>	<u>20</u>
<u>White Clay</u>	<u>20</u>	<u>24</u>
<u>Dark Clay</u>	<u>24</u>	<u>59</u>
<u>Flint (Hard)</u>	<u>59</u>	<u>63</u>
<u>Grey Shale 1 1/2 GPM</u>	<u>63</u>	<u>89</u>
<u>Sand (Hard)</u>	<u>89</u>	<u>125</u>
<u>Dark shale 8 GPM</u>	<u>125</u>	<u>130</u>
<u>Total</u>	<u>130</u>	

WELL TEST


☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 8 gpm Duration of test 24 hrs.
Drawdown to 8' of bottom ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 38 ft. Date: _____
Quality (clear, cloudy, taste, odor) _____
*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP

Type of pump Ruth Beary Capacity 12 gpm
Pump set at 120' ft.
Pump installed by Ralph Morgan

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



LOCATED
107

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm Morgan Drilling Signed Ralph Morgan
Address Box 1 Date Sept. 21, 1991
City, State, Zip Somerset, O. 43183 ODH Registration Number 1430

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

(98)