

736318

Permit Number

CONSTRUCTION DETAILS

CASING		Borehole Diameter		8 in.		GROUT		CONCRETE & Drill Cuttings	
① Diameter	6" in.	Length	69 ft.	Wall Thickness	200 in.	Material	Volume used		
② Diameter	in.	Length	ft.	Wall Thickness	in.	Method of installation	POUR		
Type:	① Steel	① Galv.	② PVC	①		Depth: placed from	68 ft.	to	0 ft.
	②	②	②	② Other		GRAVEL PACK (Filter Pack)			
Joints:	① Threaded	① Welded	② Solvent	①		Material	Volume used		
	②	②	②	② Other		Method of installation			
Liner:	Length	Type		Wall Thickness	in.	Depth: placed from	ft.	to	ft.
SCREEN						Pitless Device		☒ Adapter ☐ Preassembled unit	
Type (wire wrapped, louvered, etc.)		Material				Use of Well		HOME	
Length		ft.		Diameter		in.		☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Dug ☐ Other	
Set between		ft. and		ft.		Slot		Date of Completion 6-2-94	

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 2.5 gpm Duration of test 5 hrs.
Drawdown 175 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 75 ft. Date: 6-16-94
Quality (clear) cloudy, taste, odor _____

***(Attach a copy of the pumping test record, per section 1521.05, ORC)**

PUMP

Type of pump Sub Capacity 10 gpm
Pump set at 169 ft.
Pump installed by EARL E. STEPP

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.

N

W

E

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm FPS Drilling Signed Carl E. Hoff
Address RT 1 Box 328 Date 6-2-94
City, State, Zip HAMden Ohio ODH Registration Number 624

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy