

736519

Permit Number 11012

CONSTRUCTION DETAILS									
CASING		Borehole Diameter		8 in.		GROUT		CONCRETE	
1 Diameter	6 in.	Length	45 ft.	Wall Thickness	SDR 21 in.	Material	BENTONITE	Volume used	
2 Diameter		Length		Wall Thickness		Method of installation	POUR		
Type:	1 Steel	1 Galv.	1 PVC	1		Depth: placed from	4'	ft. to	45
	2	2	2	2 Other		GRAVEL PACK (Filter Pack)			
Joints:	1 Threaded	1 Welded	1 Solvent	1		Material		Volume used	
	2	2	2	2 Other		Method of installation			
Liner:	Length	Type		Wall Thickness		Depth: placed from		ft. to	
SCREEN					Pitless Device				
Type (wire wrapped, louvered, etc.)		Material				☒ Adapter	☐ Preassembled unit		
Length		Diameter				Use of Well	Home		
Set between		ft. and		ft.	Slot	☒ Rotary	☐ Cable	☐ Augered	☐ Driven
						☐ Dug	☐ Other		
						Date of Completion	6-12-94		

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
soil - sub soil	0	4
soft clay & shale	4	27
soft shale	27	40
med. shale	40	79
med. Dark shale	79	137
SAND stone soft	137	160
Light shale	160	240
SAND stone (med)	240	260
shale	260	280

WELL TEST

☒ Bailing ☐ Pumping* ☐ Other _____
Test rate 15 hr gpm Duration of test 2 hrs.
Drawdown 270 ft.
Measured from: ☐ top of casing ☒ ground level ☐ Other _____
Static Level (depth to water) 79 ft. Date: 6-10-94
Quality (clear, cloudy, taste, odor) _____

***(Attach a copy of the pumping test record, per section 1521.05, ORC)**

PUMP

Type of pump Sub. Capacity 10 gpm
Pump set at 275 ft.
Pump installed by EARL E. Stepp

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.

*If additional space is needed to complete well log, use next consecutively numbered form.

DNR 7802.90

Drilling Firm FPS Drilling Signed Earl E. Steff
Address RT 1 Box 328 Hamden Date 6-14-94
City, State, Zip Ohio 45634 ODH Registration Number 627

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy