

WELL LOG AND DRILLING REPORT

737644

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources, Division of Water
1939 Fountain Square Drive, Columbus, Ohio 43224 Phone (614) 265-6739

Permit Number 990

COUNTY Washington

TOWNSHIP Belpre

SECTION/LOT No. (CIRCLE ONE)

OWNER/BUILDER (CIRCLE ONE OR BOTH)

Richard P. Thomas

PROPERTY ADDRESS

1613 Wash Blvd. Belpre Oh

(ADDRESS OF WELL LOCATION A)

LOCATION OF PROPERTY

1613 Washington Blvd., Belpre, Ohio

CONSTRUCTION DETAILS

CASING Borehole Diameter 6 in. **GROUT**

[1] Diameter 6 in. Length 104 ft. Wall Thickness 0.142 in. Material _____ Volume used _____

[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation _____

Type: ☒ Steel ☒ Galv. ☐ PVC ☐ Other _____

Joints: ☒ Threaded ☐ Welded ☐ Solvent ☐ Other _____

Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.

SCREEN **GRAVEL PACK (Filter Pack)**

Type (wire wrapped, louvered, etc.) _____ Material _____

Length _____ ft. Diameter _____ in. Material _____ Volume used _____

Set between _____ ft. and _____ ft. Slot _____

Pitless Device ☒ Adapter ☐ Preassembled unit

Use of Well Private water system

☐ Rotary ☒ Cable ☐ Augered ☒ Driven ☐ Dug ☐ Other _____

Date of Completion 9-6-94

WELL LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
0 ft.	101 ft.
101	104

Sand and Gravel
Gravel

water at 104'

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____

Test rate 12 gpm Duration of test 3 hrs.

Drawdown 2 ft.

Measured from: ☒ top of casing ☐ ground level ☐ Other _____

Static Level (depth to water) 68 ft. Date: _____

Quality (clear, cloudy, taste, odor) Clear, no taste or odor

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

PUMP


Type of pump Submersible Capacity 12 gpm

Pump set at 95 ft.

Pump installed by John Board

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways,
street intersections, county roads, etc.



*If additional space is needed to complete well log, use next consecutively numbered form.

Drilling Firm

John Board water well Drilling

Signed

John Board

Address

RT 2 Box 120

Date

9-16-94

City, State, Zip

Little Hocking Oh. 45742

ODH Registration Number

586

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy

5063

DNR 7802.90