

739941

Permit Number

94 22

SECTION/LOT No.
(CIRCLE ONE)

PROPERTY ADDRESS: 11043 ELM ST. Lakeview OH
(ADDRESS OF WELL LOCATION A) 4211

(ADDRESS OF WELL LOCATION A)

CASING 6 in. Borehole Diameter 8 1/4 in. SDR17 in. **GROUT** BEAN SEAL Volume used 150

[1] Diameter 6 in. Length 82 ft. Wall Thickness SDR17 in. Material BEAN SEAL Volume used 150

[2] Diameter _____ in. Length _____ ft. Wall Thickness _____ in. Method of installation TRIM PIPE

Type: [1] Steel [1] Galv. [2] PVC [1] _____ Depth: placed from 82 ft. to SURFACE ft.

[2] _____ [2] Other _____ **GRAVEL PACK** (Filter Pack)

Joints: [1] Threaded [1] Welded [2] Solvent [1] _____ Material _____ Volume used _____

[2] _____ [2] Other _____ Method of installation _____

Liner: Length _____ Type _____ Wall Thickness _____ in. Depth: placed from _____ ft. to _____ ft.

SCREEN

Type (wire wrapped, louvered, etc.) _____ Material _____ Pitless Device [X] Adapter [] Preassembled unit

Length _____ ft. Diameter _____ in. Use of Well DOMESTIC

[X] Rotary [] Cable [] Augered [] Driven [] Dug [] Other _____

Set between _____ ft. and _____ ft. Slot _____ Date of Completion _____

WELL TEST

☐ Bailing ☒ Pumping* ☐ Other _____
 Test rate 15 gpm Duration of test 2 hrs
 Drawdown 18 FT ft.
 Measured from: ☒ Top of casing ☐ ground level ☐ Other _____
 Static Level (depth to water) 20 ft. Date: 3/8/94
 Quality (clear, cloudy, taste, odor) _____

From	To
0	30
30	40
40	82
82	105
98	102

CLAY
SAND
CLAY
Lime
WATER


***(Attach a copy of the pumping test record, per section 1521.05, ORC)**

PUMP

Type of pump SUBMERSIBLE Capacity 10 gpm
Pump set at 60 ft.
Pump installed by TOM MYERS

SKETCH SHOWING WELL LOCATION

Show distances well lies from numbered state highways, street intersections, county roads, etc.



DNR 7802.90

Signed Tom Myers
Date 2 20 94
ODH Registration Number 286

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy